

CHICOPEE FIRE DEPARTMENT

CARBON MONOXIDE INSPECTION GUIDE

I. Does this property require CO protection?

1. Does this property have fossil fuel burning equipment?
2. Does this property have an attached garage or enclosed Parking?

- * **YES to any** of the above questions requires the property to **comply** with the CO regulation.
- * **NO to both** of the above questions means the property **does not** require CO protection.

II. If **yes to any** of the above, does this property comply?

1. Is there CO protection on every habitable level of every dwelling unit of the property?
2. Is there CO protection within 10 feet of every bedroom door?
3. Are there habitable (finished) portions of basements or attics in the residence? If so, do they have co protection in them?
4. Are there any vent less gas appliances? IE: vent free fireplaces, stoves or heaters? If so, is there CO protection in the room with this appliance?
5. Does the home use a direct vent gas heating or hot Water system? If so, is there a **hardwired** CO detector in the area of the unit?

- * **YES to all** the above applicable questions indicates that the residence **does comply** with the CO regulation.
- * **NO to any** of the above applicable questions indicates that the residence **does not comply** with the CO regulation.